

Generation Dispatch Requirements to Support Flows on the New England Interface

NB to NE Transfers	NB System Load Level		
	1500 MW to 2500 MW	2501 MW to 3000 MW	3001 MW to 3500 MW
+1000 MW to - 250 MW	No Dispatch Requirements	Dispatch Requirements Exist	Dispatch Requirements Exist
- 250 MW to - 350 MW	Dispatch Requirements Exist	Dispatch Requirements Exist	Dispatch Requirements Exist
- 350 MW to - 550 MW	Dispatch Requirements Exist	Dispatch Requirements Exist	Dispatch Requirements Exist

Negative transfers indicate import into New Brunswick

Generation Dispatch Requirements with Line 3001 Out of Service and Line 3016 in Service

NB to NE Transfers		NB System Load Level			
		1500 MW to 2000 MW	2001 MW to 2500 MW	2501 MW to 3000 MW	3001 MW to 3500 MW
NB Export	500 MW to 600 MW	No Dispatch Requirements	No Dispatch Requirements	Dispatch Requirements Exist	Dispatch Requirements Exist
	400 MW to 500 MW	No Dispatch Requirements	No Dispatch Requirements	Dispatch Requirements Exist	Dispatch Requirements Exist
	300 MW to 400 MW	No Dispatch Requirements	No Dispatch Requirements	Dispatch Requirements Exist	Dispatch Requirements Exist
	200 MW to 300 MW	No Dispatch Requirements	No Dispatch Requirements	Dispatch Requirements Exist	Dispatch Requirements Exist
	100 MW to 200 MW	No Dispatch Requirements	No Dispatch Requirements	Dispatch Requirements Exist	Dispatch Requirements Exist
	0 MW to +100 MW	No Dispatch Requirements	Dispatch Requirements Exist	Dispatch Requirements Exist	Dispatch Requirements Exist
NB Import	0 to - 100 MW MW	Dispatch Requirements Exist	Dispatch Requirements Exist	Dispatch Requirements Exist	Dispatch Requirements Exist
	- 100 MW to - 200 MW	Dispatch Requirements Exist	Dispatch Requirements Exist	Dispatch Requirements Exist	Dispatch Requirements Exist
	- 200 MW to Max Import	Dispatch Requirements Exist	Dispatch Requirements Exist	Dispatch Requirements Exist	Dispatch Requirements Exist

Negative transfers indicate import into New Brunswick

Generation Dispatch Requirements with Point Lepreau Out of Service and Line 3016 and Line 3001 in Service

NB to NE Transfers	NB System Net Load Level	
	≤ 1800 MW	1801 MW to 2200 MW
+1000 MW to 0 MW	Dispatch Requirements Exist	Dispatch Requirements Exist
0 MW to - 150 MW	Dispatch Requirements Exist	Dispatch Requirements Exist
- 150 MW to - 550 MW	Dispatch Requirements Exist	Dispatch Requirements Exist

Negative transfers indicate import into New Brunswick